

## **TENDER CALL NOTICE FOR SUPPLY OF ONLINE UPS TO THE GIS CENTRE**

Sealed tenders are invited from manufacturers and authorized dealers for supply of IT Equipment to the GIS Centre of Odisha Forestry Sector Development Project, Bhubaneswar. The quantity and detailed specifications are shown in Annexure-I. The interested bidders shall submit the tender in two separate sealed packets; the 1st sealed packet containing the Technical Bid and the 2nd sealed packet containing the Price Bid. The formats for the Technical Bid and Price Bid are shown in Annexure – II & III respectively.

The technical bid should be submitted along with a Demand Draft for Rs.5, 000/- towards EMD which is refundable. Any additional information about the product in the form of pamphlets, brochures, and other product literature can also be enclosed in the technical bid. The technical bid should be submitted in a sealed cover and superscripted **“Technical Bid”**. The Technical Specification will be submitted in prescribed format as per the Annexure-II

The Price Bid should be submitted in a sealed cover super scribing on the top of the cover **“Price Bid”**. The Price Bid will be submitted in prescribed format as per the Annexure-III. Both the sealed covers containing the Technical Bid and Price Bid should be placed in one sealed cover super scribing **“TENDER FOR SUPPLY OF ONLINE UPS TO THE GIS CENTRE”** and addressed to the Deputy Project Director (A&F), Odisha Forestry Sector Development Project Phase-II, SFTRI Campus, Ghatikia, Bhubaneswar 751 029.

The Technical Bid will be scrutinized first and only the qualifying bidders will be considered for opening of the price bid. The last date and time for receipt of the tender documents in the office of the PMU of OFSDP-II is 22.02.2019 at 3.30PM. The price bid of those bidders who fail to comply with the above qualifying requirements will not be considered. The date of opening of Price bid will be communicated in due course and the price bid will be opened in the presence of qualified interested bidders who choose to be present at the time of opening.

### Terms & Conditions:

1. The technical bid should contain the following documents :
  - i) Tender specific authorization Certificate from the Original Equipment Manufacturer.
  - ii) Equivalent order copy in any Government Department executed recently inside Odisha.
  - iii) GST Registration /Latest Return Certificate.
  - iv) Income Tax Return copy for AY 2018-19 & copy of PAN Card.
  - v) EMD of Rs 5,000/- to be furnished as Demand Draft drawn in favour of Project Director, Odisha Forestry Sector Development Project Phase-II, Bhubaneswar payable at Bhubaneswar.
2. The successful bidder should supply the Items within a period of one month.
3. Failure to supply the order within the specified time will entail cancellation of orders and forfeiture of the EMD.
4. The decision of the tender accepting authority is final. The tender accepting authority reserves the right to reject any or all tenders at his/her own discretion without assigning any reason whatsoever.

Deputy Project Director (A&F)  
Odisha Forestry Sector Development Project-II

## Annexure-I

Sl No	Category	Technical Specifications		No of Units required
1	10KVA Online UPS	Make	Reputed Premium Brand APC/ Emerson / Luminous /Delta	1
		Type	True Online Uninterrupted Power Supply	
		Power Rating / Capacity	10 KVA or more at Power Factor of 0.8 or better	
		Input Voltage Range / Phase	250 Volts to 470 Volts / 3 Phase 4 wire	
		Output Voltage / Phase	230 Volts(+/- 5%) / Single Phase (Neutral, Phase, Earth)	
		Frequency(Both input and output)	50 Hz(+/- 10%)	
		Inverter Output Waveform	True Sine Wave	
		Battery Backup Time	2 Hrs or more at Full Load	
		Battery Capacity	24000 VAH or more	
		Battery Type	Maintenance Free Lead Acid Batteries	
		Bypass	Automatic bypass on fault conditions and manual bypass switch	
		Protection	Protection from Under/over voltage, overload, Short Circuit, input surge & spikes, single phase and proper insulation throughout the system	
		Warranty	Min. 5 Years or more on UPS, 2 years or more on Batteries	
		Installation and Training	Complete installation, commissioning and training on the product	

**Annexure-II**

<b>Sl No</b>	<b>Category</b>	<b>Technical Specifications</b>	<b>Compiled (Yes/No)</b>	<b>Remarks (if Any)</b>
1	10KVA Online UPS	Make		
		Type	True Online Uninterrupted Power Supply	
		Power Rating / Capacity	10 KVA or more at Power Factor of 0.8 or better	
		Input Voltage Range / Phase	250 Volts to 470 Volts / 3 Phase 4 wire	
		Output Voltage / Phase	230 Volts(+/- 5%) / Single Phase (Neutral, Phase, Earth)	
		Frequency(Both input and output)	50 Hz(+/- 10%)	
		Inverter Output Waveform	True Sine Wave	
		Battery Backup Time	2 Hrs or more at Full Load	
		Battery Capacity	24000 VAH or more	
		Battery Type	Maintenance Free Lead Acid Batteries	
		Bypass	Automatic bypass on fault conditions and manual bypass switch	
		Protection	Protection from Under/over voltage, overload, Short Circuit, input surge & spikes, single phase and proper insulation throughout the system	
		Warranty	Min. 5 Years or more on UPS, 2 years or more on Batteries	
		Installation and Training	Complete installation, commissioning and training on the product	

Bidder's Signature

**Annexure-III**

<b>Sl No</b>	<b>Category</b>	<b>Technical Specifications (Mention Make/ Model Only)</b>	<b>Unit Price Without GST</b>	<b>Quantity</b>	<b>GST %</b>	<b>GST Amount</b>	<b>Total Amount with Installation and GST</b>
1	10KVA Online UPS						

Bidder's Signature